


FIELD INSTALLATION INSTRUCTIONS

TITLE: LPNG High Limit Test and Replacement
NAME: FII-022
ISSUE DATE: 2 October 2013
REVISION: 1

PURPOSE:

The intention of this FII is to demonstrate how to perform the high limit test which should be done every heating season to ensure the burner will shut down if temperature exceeds 220 °F and to show how to replace the high limit if necessary on an IDF LPNG unit.

TOOLS REQUIRED:



From left to right: Robertson Screwdriver, Ratchet, 5/16 Socket, Cardboard to block airflow (not shown)

FIELD INSTALLATION INSTRUCTIONS

TITLE: LPNG High Limit Test and Replacement
NAME: FII-022
ISSUE DATE: 2 October 2013
REVISION: 1

PROCEDURE:




Figure 1: Resetting manual high limit



Figure 2: Blocking the fan inlet

Step 1: Press the small red button at the center of the manual high limit to reset it. See Figure 1 for an example of resetting the manual high limit.

NOTE: If you do not reset the manual high limit and it has already tripped, the burner will not turn on.

Step 2: Block the fan inlet of the unit using a cardboard wall cut to size to restrict the air flow in the unit. See Figure 2 for an example of how to block fan inlet.

NOTE: The cardboard must be cut to fit around the motor and motor mount of the fan inlet. Multiple cardboard pieces can also be used.

Step 3: Turn on the unit as you would normally.

Step 4: Let the unit run for 5 minutes to allow for the unit air temperature to increase past the acceptable limit.

FIELD INSTALLATION INSTRUCTIONS

TITLE: LPNG High Limit Test and Replacement
NAME: FII-022
ISSUE DATE: 2 October 2013
REVISION: 1




Figure 3: Location of both the high limits




Figure 4: Disconnecting the high limits to remove

Step 5: Test result interpretation:

- Only manual high limit trips → Auto high limit is defective.
- Only auto high limit trips → Auto high limit is functioning. Remove auto high limit (by bypassing it using the wiring connections) and conduct the test again to check manual high limit alone.

Step 6: To access the high limit switch, you must first remove the cover by unscrewing the two screws at its sides. See Figure 3 for high limit cover location.

Step 7: With the high limit exposed, now you can unplug the wiring and remove the screws which directly hold both the high limits to the jacket.

Step 8: Pull the high limit replace straight out and replace it with a new high limit of the appropriate temperature setting. See Figure 4 for an example of the disconnected high limits.



FIELD INSTALLATION INSTRUCTIONS

TITLE: LPNG High Limit Test and Replacement
NAME: FII-022
ISSUE DATE: 2 October 2013
REVISION: 1

Suggested High Limits		
Unit	High Limit Type	
	Automatic	Manual
IDF LPNG	200 °F	300 °F